



Republic of the Philippines
Department of Finance
INSURANCE COMMISSION
1071 United Nations Avenue, Ermita, Manila
Telephone Number: 5238462 to 70
<http://www.insurance.gov.ph>



**BIDS AND AWARDS COMMITTEE
SUPPLEMENTAL BID BULLETIN NO. 1**

**SUPPLY, DELIVERY AND INSTALLATION OF MODULAR PARTITIONS AND
OFFICE FIXTURES FOR THE INSURANCE COMMISSION
(Reference No. 16-05-132)**

This Supplemental Bid Bulletin No. 1 dated 30 May 2016 is being issued to clarify, modify, or amend items in the Bidding Documents.

The following Items in the Bidding Documents for the **Supply, Delivery and Installation of Modular Partitions and Office Fixtures for the Insurance Commission** dated 20 May 2016 are hereby revised/amended:

1. Amendment of Invitation to Bid, item no. 1, is hereby amended as follows:

From:

1. The **Insurance Commission through its Bids and Awards Committee (BAC)** intends to apply the sum of **Two Million Eight Hundred Pesos (Php2,800,000.00), inclusive of 12% VAT**, being the Approved Budget for the Contract (ABC) to payments under the contract for the **Supply, Delivery and Installation of Modular Partitions and Office Fixtures for the Insurance Commission**. Bids received in excess of the ABC shall be automatically rejected at bid opening.

To:

1. The **Insurance Commission through its Bids and Awards Committee (BAC)** intends to apply the sum of **TWO MILLION EIGHT HUNDRED THOUSAND PESOS (Php2,800,000.00), inclusive of 12% VAT**, being the Approved Budget for the Contract (ABC) to payments under the contract for the **Supply, Delivery and Installation of Modular Partitions and Office Fixtures for the Insurance Commission**. Bids received in excess of the ABC shall be automatically rejected at bid opening.
2. Amendment of Section VII. Technical Specifications and Conformity of Section VI (Schedule of Requirements) item no. 1, 3, 4 and 6 are hereby amended as follows:

From:

IC TECHNICAL SPECIFICATION			
ITEM NO.	DESCRIPTION	QTY	U/M
1	Examination Tables convertible to conference table	44	sets
	<i>d) 60mm thick Aluminum Profile system in fabric finish 750H with cable raceway</i>		
3	Floor to Ceiling Partition		
	<i>d) Size : 950W x 2950H glass in 60mm thick Aluminum Profile system in 12mm tempered glass and melamine finish with two (2) melamine swing doors</i>		
4	Roller Blinds – Chain operated roller system, #10 plated steel ball chain with upper and lower stops, roller tube aluminum with 0.060” plated steel brackets		
	<i>e) Size : 5420W x 2950H</i>	1	pc
	<i>e) Size : 5240W x 2950H</i>	1	pc
	<i>e) Size : 950W x 2950H</i>	5	Pcs
6	Examiner’s Chair	1	set
	<i>a) Leatherette seat and backrest with fixed armrest with five star nylon base and caster</i>		
7	Mid-back chair	44	Sets
	<i>d) Fabric seat and mesh backrest without armrest with five star chrome base and casters</i>		

To:

IC TECHNICAL SPECIFICATION			
ITEM NO.	DESCRIPTION	QTY	U/M
1	Examination Tables convertible to conference table	44	sets
	<u>d) 60MM THICK ALUMINUM PROFILE SYSTEM IN FABRIC FINISH 750H WITH CABLE RACEWAY (WITH 2 HOLE PROVISION)</u>		
3	Floor to Ceiling Partition		

	d) <u>SIZE : 950W X 2950H GLASS IN 60MM THICK ALUMINUM PROFILE SYSTEM IN 12MM TEMPERED GLASS AND MELAMINE FINISH</u>	<u>5</u>	<u>PCS</u>
	e) <u>MELAMINE SWING DOORS WITH DOOR LOCKS</u>	<u>2</u>	<u>PCS</u>
4	Roller Blinds – Chain operated roller system, #10 plated steel ball chain with upper and lower stops, roller tube aluminum with 0.060” plated steel brackets		
	a) <u>Window 1 and 2 - Size : 4800W x 2800H</u>	<u>2</u>	<u>lots</u>
	b) <u>Window 3 - Size : 4800W x 2100H</u>	<u>1</u>	<u>lot</u>
	c) <u>Size : 950W x 2950H (for FLOOR TO CEILING GLASS PARTITIONS)</u>	<u>5</u>	<u>Pcs</u>
6	Examiner’s Chair	<u>1</u>	<u>set</u>
	a) <u>MID-BACK</u> Leatherette seat and backrest with fixed armrest with five star nylon base and caster		
7	<u>EXAMINEE’S CHAIR</u>	<u>44</u>	<u>Sets</u>
	a) Fabric seat and mesh backrest without armrest with five star <u>NYLON BASE</u> and casters		

3. Attached are Drawings and Technical Specifications of the following:

- a. Annex “A” - Proposed Layout;
- b. Annex “B” - Examination Tables convertible to conference table;
- c. Annex “C” - Floor to Ceiling Partitions;
- d. Annex “D” – One way Operable Wall; and
- e. Annex “E” – Roller Blind

This Supplemental Bid Bulletin No. 1 shall form part of the Bid Documents. Any provisions in the Bid Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the information and guidance of all concerned.

Issued this 01 of June 2016 in the City of Manila.


BENEDICTO N. SANTOS
 Vice-Chairman
 Bids and Awards Committee

Please acknowledge by signing on the space indicated below:

Supplemental Bid Bulletin No. 1 for the **Supply, Delivery and Installation of Modular Partitions and Office Fixtures for the Insurance Commission (Project Reference No. 16-05-132)** dated 01 June 2016 consisting of four (4) pages.

Received by:



Name of the Bidder/Company: _____

Name of Authorized Representative/s: _____




Signature/s: _____

Date: _____


PROPOSED LAYOUT



EXAMINATION TABLES CONVERTIBLE TO CONFERENCE TABLE



Model: HP ProDisplay P222va



Manual Flip-Up Table

Exam Table Convertible to Conference Table

Top: 38mm thick laminate


Legs: post legs

Panel: 60mm thick partition 750h with cable raceway (with 2 hole provision)

Manual Flip-Up Table (Monitor, Keyboard, and Mouse Box)


- a. Panel size : 548x528x2 mm
- b. Hole : 507x428.5mm
- c. Material : Iron
- d. Loading Capacity : 8Kg
- e. Weight : 25Kg

FLOOR TO CEILING PARTITIONS




Floor to Ceiling Partition
Combination of tempered glass and melamine finish
60mm thick aluminum profile
With 2 doors and door locks
(refer to actual site dimension)

ONE WAY OPERABLE WALL



Operable Wall
One way
In melamine finish
(refer to actual site dimension)

ROLLER BLIND



Roller Blinds Sunscreen

Chain operated roller system

#10 plated steel ball chain with upper and lower stops,

Roller tube aluminum with 0.060" steel brackets

(Size of Windows 1 and 2: 4800W x 2800H; Window 3 : 4800W x 2100H)